



Shaping Tomorrow's
Built Environment Today

INDOOR CARBON DIOXIDE, VENTILATION AND INDOOR AIR QUALITY

THE ISSUE

Indoor CO₂ has been considered in the context of building ventilation and indoor air quality (IAQ) for centuries. Most of these discussions have focused on how CO₂ concentrations relate to occupant perceptions of IAQ, and the use of CO₂ to evaluate ventilation performance and to control of outdoor air intake rates (demand control ventilation). While these topics have been studied for decades, misinterpretation of CO₂ concentration as an indicator of IAQ and ventilation is common in the HVAC industry, IAQ research community, and the public.

In addition, recent research has studied the impact of CO₂ on human performance at commonly observed indoor concentrations. Indoor CO₂ monitoring has also been promoted as a ventilation indicator in the context of managing the risks of airborne disease transmission. Concerns have long existed regarding the accuracy of indoor CO₂ concentration measurements, which are now more common due to the availability and more widespread application of less expensive sensors. Given all of these factors, as well as increasing calls to monitor CO₂ in buildings, ASHRAE is working to clarify the use of indoor CO₂ measurements as a tool to help improve IAQ and building ventilation.

ASHRAE's ROLE

ASHRAE has long been active in providing engineering technology, standards and design guidance to support the goal of providing healthy and comfortable indoor environments in an energy-efficient manner. For decades, these efforts have focused on providing effective ventilation in buildings, designing and operating ventilation systems and managing the wide range of air pollutants within buildings. For example, ANSI/ASHRAE Standards 62.1 and 62.2 are standards that specify minimum ventilation rates and other measures to support the health, comfort and productivity of building occupants; these standards do not contain CO₂ limits based on human health and comfort.

ASHRAE Standard 62.1 contains CO₂ concentration setpoints for the application of demand control ventilation, but they are not intended to be and should not be used as indicators of IAQ.

ASHRAE's VIEW

Monitoring indoor CO₂ can be a useful tool for understanding building ventilation and IAQ, supporting efforts to provide high quality indoor environments and manage the energy needed to do so. Critically, indoor CO₂ measurements should be understood in the context of the built environment, to ensure that they are measured and interpreted in a meaningful way. Claims that ASHRAE Standard 62.1 requires indoor CO₂ concentrations below a certain threshold (typically 1000 ppm) for acceptable indoor air quality are *incorrect*.¹ ASHRAE's IAQ Standards do not use indoor CO₂ values to determine acceptable indoor air quality, as IAQ is impacted by multiple factors (such as temperature, humidity, particulate matter, gas pollutants, etc.).

¹ Persily, A. 2022. *Development and application of an indoor carbon dioxide metric*. Indoor Air. Volume 32, Issue 7.

Because of ASHRAE's mission to act for the benefit of the public, it encourages building designers, lawmakers, policymakers and others to craft informed recommendations for the measurement of indoor CO₂ concentrations. To that end, ASHRAE stresses that:

- Indoor CO₂ concentrations do not provide an overall indication of IAQ, but they can be a useful tool in IAQ assessments if users understand the limitations in these applications (e.g., number and activity level of occupants compared to the design capacity, length of time a space has been occupied, no combustion or other sources of CO₂ that could impact readings). While CO₂ readings below a threshold value do not assure overall acceptable IAQ, CO₂ readings far above expected ranges² may indicate the ventilation system is not functioning properly.
- Existing evidence for the impacts of CO₂ on health, well-being, learning outcomes and work performance is inconsistent and does not currently justify changes to ventilation and IAQ standards, regulations, and guidelines.³ However, CO₂ can be used to verify if ventilation system performance meets existing IAQ standards, regulations, and guidelines.
- The use of indoor CO₂ measurements to evaluate the risk of airborne disease transmission must account for the type of space and its occupancy and the differences in CO₂ and infectious aerosols. For example, CO₂ concentration is unaffected by filtration and most other air-cleaning methods that reduce infectious aerosol concentration, so it should not be used as a direct indicator of infection risk.
- Sensor accuracy, location and calibration are all critical for drawing meaningful inferences from measured indoor CO₂ concentrations.
- Programs or requirements to monitor CO₂ in buildings, when conducted with an understanding of their technical basis, can be helpful, but monitoring CO₂ without such understanding can lead to confusion on the part of building occupants and the public.

² *Ibid.*