

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 16-1983 (RA 99)
Method of Testing for Rating Room Air Conditioners
and Packaged Terminal Air Conditioners**

July 24, 2006

The corrections listed in this errata sheet apply to all copies of ANSI/ASHRAE Standard 16-1983 (RA 99).

<u>Page</u>	<u>Erratum</u>
-------------	----------------

9	Section 7.4.5: Revise the SI equation for “ v'_n ”
---	---

from $(v'_n = (101 - v_n) / (1 + W)P)$ to $(v'_n = (101v_n) / (1 + W)P)$