

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 20-1997
Method of Testing for Rating Remote Mechanical-Draft
Air-Cooled Refrigerant Condensers**

May 3, 2006

The corrections listed in this errata sheet apply to all versions of ANSI/ASHRAE Standard 20-1997. The outside back cover marking identifying the first printing is “GG 2/99”.

Page Erratum

- 12 **Section 11.8.1 By Calculation.** For determining the term “ η ” change “ t_{db1} and t_{db1} ” to “ t_{db1} and t_{db2} ” in the last sentence of Section 11.8.1 so it now reads: “If the motor is out of the airstream or not between measuring points for t_{db1} and t_{db2} , then

$$\eta = \frac{\text{Shaft output power}}{\text{Electrical input power}} \quad .”$$